

WASTEWATER DISCHARGE PERMIT

THE FIRM OR CORPORATION NAMED HEREIN IS AUTHORIZED TO DISCHARGE REGULATED WASTEWATER INTO THE SANITARY SEWER IN ACCORDANCE WITH ALL CONDITIONS IN THIS PERMIT AND CHAPTER 35 OF THE MOUNTAIN VIEW CITY CODE.

Permitted **Edison Pharmaceuticals, Inc.**
Facility **350 Bernardo Avenue North**

Edison Pharmaceuticals, Inc.
350 N. Bernardo Ave.
Mountain View, CA 94043
Attn: Paul Mollard

EPA Category/Subcategory: **Non-EPA Non-SIU**
Reference:

Date Issued: **5/3/2013**
Effective Date: **5/10/2013**
Date Revised:
Date Expires: **5/1/2014**
Permit ID: **594**

Jaymae Wentker
Jaymae Wentker, Fire Marshal

**POST IN A CONSPICUOUS PLACE
AT THE "PERMITTED FACILITY" SITE**

I. Discharge Limitations:

Process Discharge (industrial waste) shall not exceed 340 Gallons Per Day (GPD).
(Location A1: 340 GPD)
Total Discharge (industrial and domestic waste) shall not exceed 840 Gallons Per Day (GPD).

II. Special Conditions/Requirements:

1. Facility shall comply with laboratory 'Best Management Practices' (BMPs).
2. Employees shall be trained at least annually (and new employees within 6 months of hire) on BMPs.

III. Self-Monitoring Sampling Analysis:

| Pollutant | Sampling Frequency | Sample Type | Sampling Location(s)* | Federal Maximum for any 1 day | Federal Avg. of daily values for 30 consec. days | Local Limit |
|-----------|--------------------|-------------|-----------------------|-------------------------------|--|-------------|
| | | | | (mg/L) | (mg/L) | (mg/L) |
| | | | | | | |

*Sampling Location A1 is on sidewalk area between buildings.

IV. Wastewater Discharge Limits: (MVCC 35.32.12 & CFR 40)

Your industrial wastewater effluent shall not exceed the following limits:

| Discharge Parameter | Federal Max. for any 1 day | Federal Avg. of daily values for 30 consecutive days | Local ³ | Discharge Parameter | Federal Max. for any 1 day | Federal Avg. of daily values for 30 consecutive days | Local ³ |
|------------------------|----------------------------------|---|------------------------|-----------------------------------|----------------------------------|---|------------------------|
| Arsenic | No Limit | No Limit | 0.1 mg/L ¹ | Manganese | No Limit | No Limit | 1.0 mg/L ¹ |
| Barium | No Limit | No Limit | 5.0 mg/L ¹ | Mercury ² | No Limit | No Limit | 0.01 mg/L ² |
| Beryllium | No Limit | No Limit | 0.75 mg/L ¹ | Nickel | No Limit | No Limit | 0.5 mg/L |
| Boron | No Limit | No Limit | 1.0 mg/L ¹ | Oil & Grease | No Limit | No Limit | 200 mg/L |
| Cadmium | No Limit | No Limit | 0.1 mg/L ¹ | Phenols | No Limit | No Limit | 1.0 mg/L |
| Chromium Hex. | No Limit | No Limit | 1.0 mg/L ¹ | pH | No Limit | No Limit | 5.0-11 |
| Chromium, Total | No Limit | No Limit | 2.0 mg/L ¹ | Selenium | No Limit | No Limit | 1.0 mg/L ¹ |
| Cobalt | No Limit | No Limit | 1.0 mg/L ¹ | Silver, Photo | No Limit | No Limit | 0.50 mg/L |
| Copper ⁴ | No Limit | No Limit | 2.0 mg/L ¹ | Silver, Non-Photo | No Limit | No Limit | 0.25 mg/L |
| Copper | No Limit | No Limit | 0.25 mg/L | Single Toxic Organic | No Limit | No Limit | 0.75 mg/L |
| Cyanide | No Limit | No Limit | 0.5 mg/L ¹ | Suspended Solids | No Limit | No Limit | 6000 mg/L |
| Fluoride | No Limit | No Limit | 65 mg/L | Total Dissolved Solid | No Limit | No Limit | 10000 mg/L |
| Formaldehyde | No Limit | No Limit | 5.0 mg/L ¹ | Total Toxic Organics ⁵ | No Limit | No Limit | 1.0 mg/L |
| Lead | No Limit | No Limit | 0.5 mg/L ¹ | Zinc ⁶ | No Limit | No Limit | 2.0 mg/L ¹ |

¹If the daily discharge (averaged over a one year period) at any single sampling location exceeds 50,000 gpd, the local discharge limit for that location shall not exceed ONE-HALF (1/2) of the local limit listed above.

²Dental facilities using mercury-containing amalgam shall not exceed a local discharge limit of 0.05 mg/L for mercury.

³These limits refer to either grab or 24-hour composite samples.

⁴This limit applies only to the following EPA categories: Non-EPA Non-SIUs, Metal Finishing (Copper), and Electroplating. This limit also applies to cooling towers discharging < 2,000 gpd at any facility.

⁵See Section XIII of this permit for a list of components of Total Toxic Organics.

⁶Vehicle service facilities shall not exceed a local discharge limit of 4.0 mg/L for zinc.

V. Quality Assurance/Quality Control: (MVCC 35.32.13 & 40 CFR 136)

All metals samples must be collected in duplicate and stored and preserved until the next sampling event for that parameter. The duplicate sample must be labeled as a duplicate and made available to any City inspector.

VI. Sample Collection and Analysis: (MVCC 35.32.13.3, 40 CFR 403.12(g)&(h), 40 CFR 136)

All metals shall be collected as specified in the individual permit requirements. Cyanide and Total Toxic Organics (TTO) shall always be collected as grab samples. Samples shall be analyzed by an analytical laboratory approved by the State of Cal. Dept. of Health Services. Sample collection, preservation, and analysis shall be in accordance with EPA regulations (40 CFR 136) and the City of Mountain View's "Sample Collection, Analysis and Reporting Instructions".

VII. Violation Reporting & Follow-Up: (MVCC 35.32.6.2 & 40 CFR 403.12(f) & (g))

If the results of sampling or pH analysis exceed applicable limit(s), or any discharges meet the definition of hazardous waste, you shall:

- 1) VERBALLY NOTIFY THE CITY OF MOUNTAIN VIEW AT 650-903-6378 AND THE PALO ALTO WATER QUALITY CONTROL PLANT AT 650-329-2598 WITHIN 24 HOURS of knowledge of the violation. If an accidental discharge, slug discharge, or upset or failure of the pretreatment system occurs, verbal notification shall be made within 15 minutes of knowledge of the condition;
- 2) SUBMIT A WRITTEN REPORT WITHIN 15 WORKING DAYS of knowledge of the violation explaining: the cause, nature volume and duration of the violation, and mitigation measures taken to correct it and prevent reoccurrence;
- 3) INITIATE A SAMPLING/ANALYSIS PROGRAM demonstrating up to 21 consecutive days of compliance. The first sample result shall be submitted within 30 days of becoming aware of the violation.

VIII. Penalty Provisions: (MVCC 35.32.15)

Any person who violates any provision of this permit, "Notice of Violation", or Chapter 35 MVCC, may be subject to criminal, civil, or administrative penalties. Civil penalties shall not exceed \$25,000/day per violation. Administrative penalties shall not exceed the following: (1) \$2,000/day for failing or refusing to furnish technical or monitoring reports; (2) \$3,000/day for failing or refusing to comply with a compliance schedule; (3) \$5,000/day/violation for discharges in violation of any waste discharge limitation, permit condition, or requirement; and (4) \$10/gallon for discharges in violation of any suspension, cease and desist order, or any prohibition issued by the City.

IX. Record-Keeping Requirements: (40 CFR 403.12(o))

All Industrial Users shall maintain records for all information resulting from any monitoring activities conducted. Such records shall include for all samples:

- 1) The date, exact place, method, and time of sampling and the names of the person or persons taking the samples;
- 2) The dates analyses were performed;
- 3) Who performed the analyses;
- 4) The analytical techniques/methods used; and
- 5) The results of such analysis.

All Industrial Users shall maintain for a minimum of 3 years any records of monitoring activities and results, and shall make such records available for inspection and copying by the City of Mountain View and Palo Alto Water Quality Control Plant. This period of retention shall be extended during the course of any unresolved litigation regarding the discharge of pollutants by the Industrial User or the operation of the POTW Pretreatment Program or when requested by the Director or the Regional Administrator.

X. Notification of Changed Discharge: (40 CFR 403.12(j))

All Industrial Users shall promptly notify the City of Mountain View at 650-903-6378 and the Palo Alto Water Quality Control Plant at 650-329-2598 in advance of any substantial change in the volume or character of pollutants in their discharge, including the characteristic hazardous wastes for which the Industrial User has submitted initial notification under 40 CFR 403.12(p).

XI. Notification of Bypass: (40 CFR 403.17(c)(2))

All Industrial Users shall verbally notify the City of Mountain View at 650-903-6378 and Palo Alto Water Quality Control Plant at 650-329-2598 of an unanticipated bypass (intentional diversion of its wastestream from the treatment facility) within 24 hours from the time the Industrial User becomes aware of the bypass. A written submission shall also be provided within 5 days of the time the Industrial User becomes aware of the bypass. The written submission shall contain a description of the bypass and its cause; the duration of the bypass, including exact dates and times, and, if the bypass has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass.

XII. Transferability of Permit: (MVCC 35.32.2.4)

This permit is not transferable without prior written notification to and approval by the City and the assumption of all permit conditions by the new owner/operator.

XIII. Definition of Total Toxic Organics: (40 CFR 469.12)

The term "total toxic organics" (TTO) means the sum of the concentrations for each of the following toxic organic components found in the discharge at a concentration greater than ten (10) micrograms per liter. The facility's local TTO and STO limits apply to all of the compounds listed below. Those compounds analyzed using EPA Method 601/602 or 624 are identified by a "■".

| | | | | |
|-----------------------------|-------------------------------|------------------------------|----------------------------|----------------------|
| ■ Acenaphthene | ■ 2-Chlorophenol | ■ Methyl bromide | ■ Diethyl phthalate | ■ 4,4-DDT |
| ■ Acrolein | ■ 1,2-Dichlorobenzene | ■ Bromoform | ■ Dimethyl phthalate | ■ 4,4-DDE |
| ■ Acrylonitrile | ■ 1,3-Dichlorobenzene | ■ Dichlorobromomethane | ■ 1,2-Benzanthracene | ■ 4,4-DDD |
| ■ Benzene | ■ 1,4-Dichlorobenzene | ■ Chlorodibromomethane | ■ Benzo(a)pyrene | ■ Alpha-endosulfan |
| ■ Benzidine | ■ 3,3-Dichlorobenzidine | ■ Hexachlorobutadiene | ■ 3,4-Benzofluoranthene | ■ Beta-endosulfan |
| ■ Carbon tetrachloride | ■ 1,1-Dichloroethylene | ■ Hexachlorocyclopentadiene | ■ 11,12-Benzofluoranthene | ■ Endosulfan sulfate |
| ■ Chlorobenzene | ■ 1,2-Trans-dichloroethylene | ■ Isophorone | ■ Chrysene | ■ Endrin |
| ■ 1,2,4-Trichlorobenzene | ■ 2,4-Dichlorophenol | ■ Naphthalene | ■ Acenaphthylene | ■ Endrin aldehyde |
| ■ Hexachlorobenzene | ■ 1,2-Dichloropropane | ■ Nitrobenzene | ■ Anthracene | ■ Heptachlor |
| ■ 1,2-Dichloroethane | ■ 1,3-Dichloropropylene | ■ 2-Nitrophenol | ■ 1,12-Benzoperylene | ■ Heptachlor epoxide |
| ■ 1,1,1-Trichloroethane | ■ 2,4-Dimethylphenol | ■ 4-Nitrophenol | ■ Fluorene | ■ Alpha-BHC |
| ■ Hexachloroethane | ■ 2,4-Dinitrotoluene | ■ 2,4-Dinitrophenol | ■ Phenanthrene | ■ Beta-BHC |
| ■ 1,1-Dichloroethane | ■ 2,6-Dinitrotoluene | ■ 4,6-Dinitro-o-cresol | ■ 1,2,5,6-Dibenzanthracene | ■ Gamma-BHC |
| ■ 1,1,2-Trichloroethane | ■ 1,2-Diphenylhydrazine | ■ N-nitrosodimethylamine | ■ Indeno(1,2,3-cd) pyrene | ■ Delta-BHC |
| ■ 1,1,2,2-Tetrachloroethane | ■ Ethylbenzene | ■ N-nitrosodiphenylamine | ■ Pyrene | ■ PCB-1242 |
| ■ Chloroethane | ■ Fluoranthene | ■ N-nitrosodi-n-propylamine | ■ Tetrachloroethylene | ■ PCB-1254 |
| ■ Bis(2-chloroethyl) ether | ■ 4-Chlorophenyl phenyl ether | ■ Pentachlorophenol | ■ Toluene | ■ PCB-1221 |
| ■ 2-Chloroethyl vinyl ether | ■ 4-Bromophenyl phenyl ether | ■ Phenol | ■ Trichloroethylene | ■ PCB-1232 |
| ■ 2-Chloronaphthalene | ■ Bis(2-chloroisopropyl)ether | ■ Bis(2-ethylhexyl)phthalate | ■ Vinyl chloride | ■ PCB-1248 |
| ■ 2,4,6-Trichlorophenol | ■ Bis(2-chloroethoxy)methane | ■ Butyl benzyl phthalate | ■ Aldrin | ■ PCB-1260 |
| ■ Parachlormeta cresol | ■ Methylene chloride | ■ Di-n-butyl phthalate | ■ Dieldrin | ■ Toxaphene |
| ■ Chloroform | ■ Methyl chloride | ■ Di-n-octyl phthalate | ■ Chlordane | ■ TCDD |



*

IV. Wastewater Discharge Limits: (MVCC 35.32.12 & CFR 40)

Your industrial wastewater effluent shall not exceed the following limits:

| Discharge Parameter | Federal Max. for any 1 day | Federal Avg. of daily values for 30 consecutive days | Local ³ | Discharge Parameter | Federal Max. for any 1 day | Federal Avg. of daily values for 30 consecutive days | Local ³ |
|------------------------|----------------------------------|---|------------------------|-----------------------------------|----------------------------------|---|------------------------|
| Arsenic | No Limit | No Limit | 0.1 mg/L ¹ | Manganese | No Limit | No Limit | 1.0 mg/L ¹ |
| Barium | No Limit | No Limit | 5.0 mg/L ¹ | Mercury ² | No Limit | No Limit | 0.01 mg/L ² |
| Beryllium | No Limit | No Limit | 0.75 mg/L ¹ | Nickel | No Limit | No Limit | 0.5 mg/L |
| Boron | No Limit | No Limit | 1.0 mg/L ¹ | Oil & Grease | No Limit | No Limit | 200 mg/L |
| Cadmium | No Limit | No Limit | 0.1 mg/L ¹ | Phenols | No Limit | No Limit | 1.0 mg/L |
| Chromium Hex. | No Limit | No Limit | 1.0 mg/L ¹ | pH | No Limit | No Limit | 5.0-11 |
| Chromium, Total | No Limit | No Limit | 2.0 mg/L ¹ | Selenium | No Limit | No Limit | 1.0 mg/L ¹ |
| Cobalt | No Limit | No Limit | 1.0 mg/L ¹ | Silver, Photo | No Limit | No Limit | 0.50 mg/L |
| Copper ⁴ | No Limit | No Limit | 2.0 mg/L ¹ | Silver, Non-Photo | No Limit | No Limit | 0.25 mg/L |
| Copper | No Limit | No Limit | 0.25 mg/L | Single Toxic Organic | No Limit | No Limit | 0.75 mg/L |
| Cyanide | No Limit | No Limit | 0.5 mg/L ¹ | Suspended Solids | No Limit | No Limit | 6000 mg/L |
| Fluoride * | No Limit | No Limit | 65 mg/L | Total Dissolved Solid | No Limit | No Limit | 10000 mg/L |
| Formaldehyde | No Limit | No Limit | 5.0 mg/L ¹ | Total Toxic Organics ⁵ | No Limit | No Limit | 1.0 mg/L |
| Lead | No Limit | No Limit | 0.5 mg/L ¹ | Zinc ⁶ | No Limit | No Limit | 2.0 mg/L ¹ |

¹If the daily discharge (averaged over a one year period) at any single sampling location exceeds 50,000 gpd, the local discharge limit for that location shall not exceed ONE-HALF (1/2) of the local limit listed above.

²Dental facilities using mercury-containing amalgam shall not exceed a local discharge limit of 0.05 mg/L for mercury.

³These limits refer to either grab or 24-hour composite samples.

⁴This limit applies only to the following EPA categories: Non-EPA Non-SIUs, Metal Finishing (Copper), and Electroplating. This limit also applies to cooling towers discharging < 2,000 gpd at any facility.

⁵See Section XIII of this permit for a list of components of Total Toxic Organics.

⁶Vehicle service facilities shall not exceed a local discharge limit of 4.0 mg/L for zinc.

V. Quality Assurance/Quality Control: (MVCC 35.32.13 & 40 CFR 136)

All metals samples must be collected in duplicate and stored and preserved until the next sampling event for that parameter. The duplicate sample must be labeled as a duplicate and made available to any City inspector.

VI. Sample Collection and Analysis: (MVCC 35.32.13.3, 40 CFR 403.12(g)&(h), 40 CFR 136)

All metals shall be collected as specified in the individual permit requirements. Cyanide and Total Toxic Organics (TTO) shall always be collected as grab samples. Samples shall be analyzed by an analytical laboratory approved by the State of Cal. Dept. of Health Services. Sample collection, preservation, and analysis shall be in accordance with EPA regulations (40 CFR 136) and the City of Mountain View's "Sample Collection, Analysis and Reporting Instructions".

VII. Violation Reporting & Follow-Up: (MVCC 35.32.6.2 & 40 CFR 403.12(f) & (g))

If the results of sampling or pH analysis exceed applicable limit(s), or any discharges meet the definition of hazardous waste, you shall:

- 1) VERBALLY NOTIFY THE CITY OF MOUNTAIN VIEW AT 650-903-6378 AND THE PALO ALTO WATER QUALITY CONTROL PLANT AT 650-329-2598 WITHIN 24 HOURS of knowledge of the violation. If an accidental discharge, slug discharge, or upset or failure of the pretreatment system occurs, verbal notification shall be made within 15 minutes of knowledge of the condition;
- 2) SUBMIT A WRITTEN REPORT WITHIN 15 WORKING DAYS of knowledge of the violation explaining: the cause, nature volume and duration of the violation, and mitigation measures taken to correct it and prevent reoccurrence;
- 3) INITIATE A SAMPLING/ANALYSIS PROGRAM demonstrating up to 21 consecutive days of compliance. The first sample result shall be submitted within 30 days of becoming aware of the violation.

VIII. Penalty Provisions: (MVCC 35.32.15)

Any person who violates any provision of this permit, "Notice of Violation", or Chapter 35 MVCC, may be subject to criminal, civil, or administrative penalties. Civil penalties shall not exceed \$25,000/day per violation. Administrative penalties shall not exceed the following: (1) \$2,000/day for failing or refusing to furnish technical or monitoring reports; (2) \$3,000/day for failing or refusing to comply with a compliance schedule; (3) \$5,000/day/violation for discharges in violation of any waste discharge limitation, permit condition, or requirement; and (4) \$10/gallon for discharges in violation of any suspension, cease and desist order, or any prohibition issued by the City.

IX. Record-Keeping Requirements: (40 CFR 403.12(o))

All Industrial Users shall maintain records for all information resulting from any monitoring activities conducted. Such records shall include for all samples:

- 1) The date, exact place, method, and time of sampling and the names of the person or persons taking the samples;
- 2) The dates analyses were performed;
- 3) Who performed the analyses;
- 4) The analytical techniques/methods used; and
- 5) The results of such analysis.

All Industrial Users shall maintain for a minimum of 3 years any records of monitoring activities and results, and shall make such records available for inspection and copying by the City of Mountain View and Palo Alto Water Quality Control Plant. This period of retention shall be extended during the course of any unresolved litigation regarding the discharge of pollutants by the Industrial User or the operation of the POTW Pretreatment Program or when requested by the Director or the Regional Administrator.

X. Notification of Changed Discharge: (40 CFR 403.12(j))

All Industrial Users shall promptly notify the City of Mountain View at 650-903-6378 and the Palo Alto Water Quality Control Plant at 650-329-2598 in advance of any substantial change in the volume or character of pollutants in their discharge, including the characteristic hazardous wastes for which the Industrial User has submitted initial notification under 40 CFR 403.12(p).

XI. Notification of Bypass: (40 CFR 403.17(c)(2))

All Industrial Users shall verbally notify the City of Mountain View at 650-903-6378 and Palo Alto Water Quality Control Plant at 650-329-2598 of an unanticipated bypass (intentional diversion of its wastestream from the treatment facility) within 24 hours from the time the Industrial User becomes aware of the bypass. A written submission shall also be provided within 5 days of the time the Industrial User becomes aware of the bypass. The written submission shall contain a description of the bypass and its cause; the duration of the bypass, including exact dates and times, and, if the bypass has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass.

XII. Transferability of Permit: (MVCC 35.32.2.4)

This permit is not transferable without prior written notification to and approval by the City and the assumption of all permit conditions by the new owner/operator.

XIII. Definition of Total Toxic Organics: (40 CFR 469.12)

The term "total toxic organics" (TTO) means the sum of the concentrations for each of the following toxic organic components found in the discharge at a concentration greater than ten (10) micrograms per liter. The facility's local TTO and STO limits apply to all of the compounds listed below. Those compounds analyzed using EPA Method 601/602 or 624 are identified by a "■".

| | | | | |
|----------------------------|------------------------------|-----------------------------|---------------------------|---------------------|
| ■Acenaphthene | ■2-Chlorophenol | ■Methyl bromide | ■Diethyl phthalate | ■4,4-DDT |
| ■Acrolein | ■1,2-Dichlorobenzene | ■Bromoform | ■Dimethyl phthalate | ■4,4-DDE |
| ■Acrylonitrile | ■1,3-Dichlorobenzene | ■Dichlorobromomethane | ■1,2-Benzanthracene | ■4,4-DDD |
| ■Benzene | ■1,4-Dichlorobenzene | ■Chlorodibromomethane | ■Benzo(a)pyrene | ■Alpha-endosulfan |
| ■Benzidine | ■3,3-Dichlorobenzidine | ■Hexachlorobutadiene | ■3,4-Benzofluoranthene | ■Beta-endosulfan |
| ■Carbon tetrachloride | ■1,1-Dichloroethylene | ■Hexachlorocyclopentadiene | ■1,1,12-Benzofluoranthene | ■Endosulfan sulfate |
| ■Chlorobenzene | ■1,2-Trans-dichloroethylene | ■Isophorone | ■Chrysene | ■Endrin |
| ■1,2,4-Trichlorobenzene | ■2,4-Dichlorophenol | ■Naphthalene | ■Acenaphthylene | ■Endrin aldehyde |
| ■Hexachlorobenzene | ■1,2-Dichloropropane | ■Nitrobenzene | ■Anthracene | ■Heptachlor |
| ■1,2-Dichloroethane | ■1,3-Dichloropropylene | ■2-Nitrophenol | ■1,12-Benzoperylene | ■Heptachlor epoxide |
| ■1,1,1-Trichloroethane | ■2,4-Dimethylphenol | ■4-Nitrophenol | ■Fluorene | ■Alpha-BHC |
| ■Hexachloroethane | ■2,4-Dinitrotoluene | ■2,4-Dinitrophenol | ■Phenanthrene | ■Beta-BHC |
| ■1,1-Dichloroethane | ■2,6-Dinitrotoluene | ■4,6-Dinitro-o-cresol | ■1,2,5,6-Dibenzanthracene | ■Gamma-BHC |
| ■1,1,2-Trichloroethane | ■1,2-Diphenylhydrazine | ■N-nitrosodimethylamine | ■Indeno(1,2,3-cd) pyrene | ■Delta-BHC |
| ■1,1,2,2-Tetrachloroethane | ■Ethylbenzene | ■N-nitrosodiphenylamine | ■Pyrene | ■PCB-1242 |
| ■Chloroethane | ■Fluoranthene | ■N-nitrosodi-n-propylamine | ■Tetrachloroethylene | ■PCB-1254 |
| ■Bis(2-chloroethyl) ether | ■4-Chlorophenyl phenyl ether | ■Pentachlorophenol | ■Toluene | ■PCB-1221 |
| ■2-Chloroethyl vinyl ether | ■4-Bromophenyl phenyl ether | ■Phenol | ■Trichloroethylene | ■PCB-1232 |
| ■2-Chloronaphthalene | ■Bis(2-chloroisopropyl)ether | ■Bis(2-ethylhexyl)phthalate | ■Vinyl chloride | ■PCB-1248 |
| ■2,4,6-Trichlorophenol | ■Bis(2-chloroethoxy)methane | ■Butyl benzyl phthalate | ■Aldrin | ■PCB-1260 |
| ■Parachlormeta cresol | ■Methylene chloride | ■Di-n-butyl phthalate | ■Dieldrin | ■Toxaphene |
| ■Chloroform | ■Methyl chloride | ■Di-n-octyl phthalate | ■Chlordane | ■TCDD |

**WASTEWATER DISCHARGE
PERMIT**

THE FIRM OR CORPORATION NAMED HEREIN IS AUTHORIZED TO DISCHARGE REGULATED WASTEWATER INTO THE SANITARY SEWER IN ACCORDANCE WITH ALL CONDITIONS IN THIS PERMIT AND CHAPTER 35 OF THE MOUNTAIN VIEW CITY CODE.

Permitted **Siemens Business Unit Ultrasound**
Facility **685 Middlefield Road East**

Siemens Business Unit Ultrasound
P.O. Box 7393
Mountain View, CA 94039-7393
Attn: Scott Turner

Date Issued: 4/25/2013

Effective Date: 5/2/2013

Date Revised: 5/16/2013

Date Expires: 5/1/2014

Permit ID: 524

EPA Category/Subcategory: **Non-EPA Non-SIU**
Reference:

Jaymae Wentker
Jaymae Wentker, Fire Marshal

 **POST IN A CONSPICUOUS PLACE
AT THE "PERMITTED FACILITY" SITE** 

I. Discharge Limitations:

Process Discharge (industrial waste) shall not exceed 1,353 Gallons Per Day (GPD).

(Location A1: 1353 GPD)

Total Discharge (industrial and domestic waste) shall not exceed 8,453 Gallons Per Day (GPD).

II. Special Conditions/Requirements:

1. Facility shall comply with laboratory 'Best Management Practices' (BMPs).
2. Employees shall be trained at least annually (and new employees within 6 months of hire) on BMPs.

III. Self-Monitoring Sampling Analysis:

| III. Self-Monitoring Sampling Analysis: | | | | Federal | Avg. of daily | Local |
|---|--------------------|-------------|-----------------------|---------------|---------------|--------|
| Pollutant | Sampling Frequency | Sample Type | Sampling Location(s)* | Maximum | values for 30 | Limit |
| | | | | for any 1 day | consec.days | |
| | | | | (mg/L) | (mg/L) | (mg/L) |
| | | | | | | |

*Sampling Location A1 is at hazmat Location 12.

IV. Wastewater Discharge Limits: (MVCC 35.32.12 & CFR 40)

Your industrial wastewater effluent shall not exceed the following limits:

| Discharge Parameter | Federal Max. for any 1 day | Federal Avg. of daily values for 30 consecutive days | Local ³ | Discharge Parameter | Federal Max. for any 1 day | Federal Avg. of daily values for 30 consecutive days | Local ³ |
|------------------------|----------------------------------|---|------------------------|-----------------------------------|----------------------------------|---|------------------------|
| Arsenic | No Limit | No Limit | 0.1 mg/L ¹ | Manganese | No Limit | No Limit | 1.0 mg/L ¹ |
| Barium | No Limit | No Limit | 5.0 mg/L ¹ | Mercury ² | No Limit | No Limit | 0.01 mg/L ² |
| Beryllium | No Limit | No Limit | 0.75 mg/L ¹ | Nickel | No Limit | No Limit | 0.5 mg/L |
| Boron | No Limit | No Limit | 1.0 mg/L ¹ | Oil & Grease | No Limit | No Limit | 200 mg/L |
| Cadmium | No Limit | No Limit | 0.1 mg/L ¹ | Phenols | No Limit | No Limit | 1.0 mg/L |
| Chromium Hex. | No Limit | No Limit | 1.0 mg/L ¹ | pH | No Limit | No Limit | 5.0-11 |
| Chromium, Total | No Limit | No Limit | 2.0 mg/L ¹ | Selenium | No Limit | No Limit | 1.0 mg/L ¹ |
| Cobalt | No Limit | No Limit | 1.0 mg/L ¹ | Silver, Photo | No Limit | No Limit | 0.50 mg/L |
| Copper ⁴ | No Limit | No Limit | 2.0 mg/L ¹ | Silver, Non-Photo | No Limit | No Limit | 0.25 mg/L |
| Copper | No Limit | No Limit | 0.25 mg/L | Single Toxic Organic | No Limit | No Limit | 0.75 mg/L |
| Cyanide | No Limit | No Limit | 0.5 mg/L ¹ | Suspended Solids | No Limit | No Limit | 6000 mg/L |
| Fluoride | No Limit | No Limit | 65 mg/L | Total Dissolved Solid | No Limit | No Limit | 10000 mg/L |
| Formaldehyde | No Limit | No Limit | 5.0 mg/L ¹ | Total Toxic Organics ⁵ | No Limit | No Limit | 1.0 mg/L |
| Lead | No Limit | No Limit | 0.5 mg/L ¹ | Zinc ⁶ | No Limit | No Limit | 2.0 mg/L ¹ |

¹If the daily discharge (averaged over a one year period) at any single sampling location exceeds 50,000 gpd, the local discharge limit for that location shall not exceed ONE-HALF (1/2) of the local limit listed above.

²Dental facilities using mercury-containing amalgam shall not exceed a local discharge limit of 0.05 mg/L for mercury.

³These limits refer to either grab or 24-hour composite samples.

⁴This limit applies only to the following EPA categories: Non-EPA Non-SIUs, Metal Finishing (Copper), and Electroplating. This limit also applies to cooling towers discharging < 2,000 gpd at any facility.

⁵See Section XIII of this permit for a list of components of Total Toxic Organics.

⁶Vehicle service facilities shall not exceed a local discharge limit of 4.0 mg/L for zinc.

V. Quality Assurance/Quality Control: (MVCC 35.32.13 & 40 CFR 136)

All metals samples must be collected in duplicate and stored and preserved until the next sampling event for that parameter. The duplicate sample must be labeled as a duplicate and made available to any City inspector.

VI. Sample Collection and Analysis: (MVCC 35.32.13.3, 40 CFR 403.12(g)&(h), 40 CFR 136)

All metals shall be collected as specified in the individual permit requirements. Cyanide and Total Toxic Organics (TTO) shall always be collected as grab samples. Samples shall be analyzed by an analytical laboratory approved by the State of Cal. Dept. of Health Services. Sample collection, preservation, and analysis shall be in accordance with EPA regulations (40 CFR 136) and the City of Mountain View's "Sample Collection, Analysis and Reporting Instructions".

VII. Violation Reporting & Follow-Up: (MVCC 35.32.6.2 & 40 CFR 403.12(f) & (g))

If the results of sampling or pH analysis exceed applicable limit(s), or any discharges meet the definition of hazardous waste, you shall:

- 1) VERBALLY NOTIFY THE CITY OF MOUNTAIN VIEW AT 650-903-6378 AND THE PALO ALTO WATER QUALITY CONTROL PLANT AT 650-329-2598 WITHIN 24 HOURS of knowledge of the violation. If an accidental discharge, slug discharge, or upset or failure of the pretreatment system occurs, verbal notification shall be made within 15 minutes of knowledge of the condition;
- 2) SUBMIT A WRITTEN REPORT WITHIN 15 WORKING DAYS of knowledge of the violation explaining: the cause, nature volume and duration of the violation, and mitigation measures taken to correct it and prevent reoccurrence;
- 3) INITIATE A SAMPLING/ANALYSIS PROGRAM demonstrating up to 21 consecutive days of compliance. The first sample result shall be submitted within 30 days of becoming aware of the violation.

VIII. Penalty Provisions: (MVCC 35.32.15)

Any person who violates any provision of this permit, "Notice of Violation", or Chapter 35 MVCC, may be subject to criminal, civil, or administrative penalties. Civil penalties shall not exceed \$25,000/day per violation. Administrative penalties shall not exceed the following: (1) \$2,000/day for failing or refusing to furnish technical or monitoring reports; (2) \$3,000/day for failing or refusing to comply with a compliance schedule; (3) \$5,000/day/violation for discharges in violation of any waste discharge limitation, permit condition, or requirement; and (4) \$10/gallon for discharges in violation of any suspension, cease and desist order, or any prohibition issued by the City.

IX. Record-Keeping Requirements: (40 CFR 403.12(o))

All Industrial Users shall maintain records for all information resulting from any monitoring activities conducted. Such records shall include for all samples:

- 1) The date, exact place, method, and time of sampling and the names of the person or persons taking the samples;
- 2) The dates analyses were performed;
- 3) Who performed the analyses;
- 4) The analytical techniques/methods used; and
- 5) The results of such analysis.

All Industrial Users shall maintain for a minimum of 3 years any records of monitoring activities and results, and shall make such records available for inspection and copying by the City of Mountain View and Palo Alto Water Quality Control Plant. This period of retention shall be extended during the course of any unresolved litigation regarding the discharge of pollutants by the Industrial User or the operation of the POTW Pretreatment Program or when requested by the Director or the Regional Administrator.

X. Notification of Changed Discharge: (40 CFR 403.12(j))

All Industrial Users shall promptly notify the City of Mountain View at 650-903-6378 and the Palo Alto Water Quality Control Plant at 650-329-2598 in advance of any substantial change in the volume or character of pollutants in their discharge, including the characteristic hazardous wastes for which the Industrial User has submitted initial notification under 40 CFR 403.12(p).

XI. Notification of Bypass: (40 CFR 403.17(c)(2))

All Industrial Users shall verbally notify the City of Mountain View at 650-903-6378 and Palo Alto Water Quality Control Plant at 650-329-2598 of an unanticipated bypass (intentional diversion of its wastestream from the treatment facility) within 24 hours from the time the Industrial User becomes aware of the bypass. A written submission shall also be provided within 5 days of the time the Industrial User becomes aware of the bypass. The written submission shall contain a description of the bypass and its cause; the duration of the bypass, including exact dates and times, and, if the bypass has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent recurrence of the bypass.

XII. Transferability of Permit: (MVCC 35.32.2.4)

This permit is not transferable without prior written notification to and approval by the City and the assumption of all permit conditions by the new owner/operator.

XIII. Definition of Total Toxic Organics: (40 CFR 469.12)

The term "total toxic organics" (TTO) means the sum of the concentrations for each of the following toxic organic components found in the discharge at a concentration greater than ten (10) micrograms per liter. The facility's local TTO and STO limits apply to all of the compounds listed below. Those compounds analyzed using EPA Method 601/602 or 624 are identified by a "■".

| | | | | |
|----------------------------|------------------------------|-----------------------------|---------------------------|---------------------|
| ■Acenaphthene | ■2-Chlorophenol | ■Methyl bromide | ■Diethyl phthalate | ■4,4-DDT |
| ■Acrolein | ■1,2-Dichlorobenzene | ■Bromoform | ■Dimethyl phthalate | ■4,4-DDE |
| ■Acrylonitrile | ■1,3-Dichlorobenzene | ■Dichlorobromomethane | ■1,2-Benzanthracene | ■4,4-DDD |
| ■Benzene | ■1,4-Dichlorobenzene | ■Chlorodibromomethane | ■Benzo(a)pyrene | ■Alpha-endosulfan |
| ■Benzidine | ■3,3-Dichlorobenzidine | ■Hexachlorobutadiene | ■3,4-Benzofluoranthene | ■Beta-endosulfan |
| ■Carbon tetrachloride | ■1,1-Dichloroethylene | ■Hexachlorocyclopentadiene | ■1,1,12-Benzofluoranthene | ■Endosulfan sulfate |
| ■Chlorobenzene | ■1,2-Trans-dichloroethylene | ■Isophorone | ■Chrysene | ■Endrin |
| ■1,2,4-Trichlorobenzene | ■2,4-Dichlorophenol | ■Naphthalene | ■Acenaphthylene | ■Endrin aldehyde |
| ■Hexachlorobenzene | ■1,2-Dichloropropane | ■Nitrobenzene | ■Anthracene | ■Heptachlor |
| ■1,2-Dichloroethane | ■1,3-Dichloropropylene | ■2-Nitrophenol | ■1,12-Benzoperylene | ■Heptachlor epoxide |
| ■1,1,1-Trichloroethane | ■2,4-Dimethylphenol | ■4-Nitrophenol | ■Fluorene | ■Alpha-BHC |
| ■Hexachloroethane | ■2,4-Dinitrotoluene | ■2,4-Dinitrophenol | ■Phenanthrene | ■Beta-BHC |
| ■1,1-Dichloroethane | ■2,6-Dinitrotoluene | ■4,6-Dinitro-o-cresol | ■1,2,5,6-Dibenzanthracene | ■Gamma-BHC |
| ■1,1,2-Trichloroethane | ■1,2-Diphenylhydrazine | ■N-nitrosodimethylamine | ■Indeno(1,2,3-cd) pyrene | ■Delta-BHC |
| ■1,1,2,2-Tetrachloroethane | ■Ethylbenzene | ■N-nitrosodiphenylamine | ■Pyrene | ■PCB-1242 |
| ■Chloroethane | ■Fluoranthene | ■N-nitrosodi-n-propylamine | ■Tetrachloroethylene | ■PCB-1254 |
| ■Bis(2-chloroethyl) ether | ■4-Chlorophenyl phenyl ether | ■Pentachlorophenol | ■Toluene | ■PCB-1221 |
| ■2-Chloroethyl vinyl ether | ■4-Bromophenyl phenyl ether | ■Phenol | ■Trichloroethylene | ■PCB-1232 |
| ■2-Chloronaphthalene | ■Bis(2-chloroisopropyl)ether | ■Bis(2-ethylhexyl)phthalate | ■Vinyl chloride | ■PCB-1248 |
| ■2,4,6-Trichlorophenol | ■Bis(2-chloroethoxy)methane | ■Butyl benzyl phthalate | ■Aldrin | ■PCB-1260 |
| ■Parachlorometa cresol | ■Methylene chloride | ■Di-n-butyl phthalate | ■Dieldrin | ■Toxaphene |
| ■Chloroform | ■Methyl chloride | ■Di-n-octyl phthalate | ■Chlordane | ■TCDD |

WASTEWATER DISCHARGE PERMIT

THE FIRM OR CORPORATION NAMED HEREIN IS AUTHORIZED TO DISCHARGE REGULATED WASTEWATER INTO THE SANITARY SEWER IN ACCORDANCE WITH ALL CONDITIONS IN THIS PERMIT AND CHAPTER 35 OF THE MOUNTAIN VIEW CITY CODE.

Permitted **Progenitor Cell Therapy, LLC**
Facility **291 Bernardo Avenue North**

Progenitor Cell Therapy, LLC
291 North Bernardo Ave.
Mountain View, CA 94043
Attn: Eddie Silva

Date Issued: **4/23/2014**
Effective Date: **4/30/2014**
Date Revised:
Date Expires: **5/1/2015**
Permit ID: **558**

EPA Category/Subcategory: **Non-EPA Non-SIU**
Reference:

Jaymae Wentker
Jaymae Wentker, Fire Marshal

**POST IN A CONSPICUOUS PLACE
AT THE "PERMITTED FACILITY" SITE**

I. Discharge Limitations:

Process Discharge (industrial waste) shall not exceed 360 Gallons Per Day (GPD).
(Location A1: 360 GPD)
Total Discharge (industrial and domestic waste) shall not exceed 1,110 Gallons Per Day (GPD).

II. Special Conditions/Requirements:

1. Facility shall comply with all laboratory "Best Management Practices" (BMPs).
2. Employees shall be trained at least annually (and new employees within 6 months of hire) on BMPs.

III. Self-Monitoring Sampling Analysis:

| Pollutant | Sampling Frequency | Sample Type | Sampling Location(s)* | Federal | Federal | Local Limit (mg/L) |
|-----------|--------------------|-------------|-----------------------|------------------------------------|---|-----------------------|
| | | | | Maximum for any 1 day (mg/L) | Avg. of daily values for 30 consec.days (mg/L) | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |

*

IV. Wastewater Discharge Limits: (MVCC 35.32.12 & CFR 40)

Your industrial wastewater effluent shall not exceed the following limits:

| Discharge Parameter | Federal Max. for any 1 day | Federal Avg. of daily values for 30 consecutive days | Local ³ | Discharge Parameter | Federal Max. for any 1 day | Federal Avg. of daily values for 30 consecutive days | Local ³ |
|------------------------|----------------------------------|---|------------------------|-----------------------------------|----------------------------------|---|------------------------|
| Arsenic | No Limit | No Limit | 0.1 mg/L ¹ | Manganese | No Limit | No Limit | 1.0 mg/L ¹ |
| Barium | No Limit | No Limit | 5.0 mg/L ¹ | Mercury ² | No Limit | No Limit | 0.01 mg/L ² |
| Beryllium | No Limit | No Limit | 0.75 mg/L ¹ | Nickel | No Limit | No Limit | 0.5 mg/L |
| Boron | No Limit | No Limit | 1.0 mg/L ¹ | Oil & Grease | No Limit | No Limit | 200 mg/L |
| Cadmium | No Limit | No Limit | 0.1 mg/L ¹ | Phenols | No Limit | No Limit | 1.0 mg/L |
| Chromium Hex. | No Limit | No Limit | 1.0 mg/L ¹ | pH | No Limit | No Limit | 5.0-11 |
| Chromium, Total | No Limit | No Limit | 2.0 mg/L ¹ | Selenium | No Limit | No Limit | 1.0 mg/L ¹ |
| Cobalt | No Limit | No Limit | 1.0 mg/L ¹ | Silver, Photo | No Limit | No Limit | 0.50 mg/L |
| Copper ⁴ | No Limit | No Limit | 2.0 mg/L ¹ | Silver, Non-Photo | No Limit | No Limit | 0.25 mg/L |
| Copper | No Limit | No Limit | 0.25 mg/L | Single Toxic Organic | No Limit | No Limit | 0.75 mg/L |
| Cyanide | No Limit | No Limit | 0.5 mg/L ¹ | Suspended Solids | No Limit | No Limit | 6000 mg/L |
| Fluoride | No Limit | No Limit | 65 mg/L | Total Dissolved Solid | No Limit | No Limit | 10000 mg/L |
| Formaldehyde | No Limit | No Limit | 5.0 mg/L ¹ | Total Toxic Organics ⁵ | No Limit | No Limit | 1.0 mg/L |
| Lead | No Limit | No Limit | 0.5 mg/L ¹ | Zinc ⁶ | No Limit | No Limit | 2.0 mg/L ¹ |

¹If the daily discharge (averaged over a one year period) at any single sampling location exceeds 50,000 gpd, the local discharge limit for that location shall not exceed ONE-HALF (1/2) of the local limit listed above.

²Dental facilities using mercury-containing amalgam shall not exceed a local discharge limit of 0.05 mg/L for mercury.

³These limits refer to either grab or 24-hour composite samples.

⁴This limit applies only to the following EPA categories: Non-EPA Non-SIUs, Metal Finishing (Copper), and Electroplating. This limit also applies to cooling towers discharging < 2,000 gpd at any facility.

⁵See Section XIII of this permit for a list of components of Total Toxic Organics.

⁶Vehicle service facilities shall not exceed a local discharge limit of 4.0 mg/L for zinc.

V. Quality Assurance/Quality Control: (MVCC 35.32.13 & 40 CFR 136)

All metals samples must be collected in duplicate and stored and preserved until the next sampling event for that parameter. The duplicate sample must be labeled as a duplicate and made available to any City inspector.

VI. Sample Collection and Analysis: (MVCC 35.32.13.3, 40 CFR 403.12(g)&(h), 40 CFR 136)

All metals shall be collected as specified in the individual permit requirements. Cyanide and Total Toxic Organics (TTO) shall always be collected as grab samples. Samples shall be analyzed by an analytical laboratory approved by the State of Cal. Dept. of Health Services. Sample collection, preservation, and analysis shall be in accordance with EPA regulations (40 CFR 136) and the City of Mountain View's "Sample Collection, Analysis and Reporting Instructions".

VII. Violation Reporting & Follow-Up: (MVCC 35.32.6.2 & 40 CFR 403.12(f) & (g))

If the results of sampling or pH analysis exceed applicable limit(s), or any discharges meet the definition of hazardous waste, you shall:

- 1) VERBALLY NOTIFY THE CITY OF MOUNTAIN VIEW AT 650-903-6378 AND THE PALO ALTO WATER QUALITY CONTROL PLANT AT 650-329-2598 WITHIN 24 HOURS of knowledge of the violation. If an accidental discharge, slug discharge, or upset or failure of the pretreatment system occurs, verbal notification shall be made within 15 minutes of knowledge of the condition;
- 2) SUBMIT A WRITTEN REPORT WITHIN 15 WORKING DAYS of knowledge of the violation explaining: the cause, nature volume and duration of the violation, and mitigation measures taken to correct it and prevent reoccurrence;
- 3) INITIATE A SAMPLING/ANALYSIS PROGRAM demonstrating up to 21 consecutive days of compliance. The first sample result shall be submitted within 30 days of becoming aware of the violation.

VIII. Penalty Provisions: (MVCC 35.32.15)

Any person who violates any provision of this permit, "Notice of Violation", or Chapter 35 MVCC, may be subject to criminal, civil, or administrative penalties. Civil penalties shall not exceed \$25,000/day per violation. Administrative penalties shall not exceed the following: (1) \$2,000/day for failing or refusing to furnish technical or monitoring reports; (2) \$3,000/day for failing or refusing to comply with a compliance schedule; (3) \$5,000/day/violation for discharges in violation of any waste discharge limitation, permit condition, or requirement; and (4) \$10/gallon for discharges in violation of any suspension, cease and desist order, or any prohibition issued by the City.

IX. Record-Keeping Requirements: (40 CFR 403.12(o))

All Industrial Users shall maintain records for all information resulting from any monitoring activities conducted. Such records shall include for all samples:

- 1) The date, exact place, method, and time of sampling and the names of the person or persons taking the samples;
- 2) The dates analyses were performed;
- 3) Who performed the analyses;
- 4) The analytical techniques/methods used; and
- 5) The results of such analysis.

All Industrial Users shall maintain for a minimum of 3 years any records of monitoring activities and results, and shall make such records available for inspection and copying by the City of Mountain View and Palo Alto Water Quality Control Plant. This period of retention shall be extended during the course of any unresolved litigation regarding the discharge of pollutants by the Industrial User or the operation of the POTW Pretreatment Program or when requested by the Director or the Regional Administrator.

X. Notification of Changed Discharge: (40 CFR 403.12(j))

All Industrial Users shall promptly notify the City of Mountain View at 650-903-6378 and the Palo Alto Water Quality Control Plant at 650-329-2598 in advance of any substantial change in the volume or character of pollutants in their discharge, including the characteristic hazardous wastes for which the Industrial User has submitted initial notification under 40 CFR 403.12(p).

XI. Notification of Bypass: (40 CFR 403.17(c)(2))

All Industrial Users shall verbally notify the City of Mountain View at 650-903-6378 and Palo Alto Water Quality Control Plant at 650-329-2598 of an unanticipated bypass (intentional diversion of its wastestream from the treatment facility) within 24 hours from the time the Industrial User becomes aware of the bypass. A written submission shall also be provided within 5 days of the time the Industrial User becomes aware of the bypass. The written submission shall contain a description of the bypass and its cause; the duration of the bypass, including exact dates and times, and, if the bypass has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass.

XII. Transferability of Permit: (MVCC 35.32.2.4)

This permit is not transferable without prior written notification to and approval by the City and the assumption of all permit conditions by the new owner/operator.

XIII. Definition of Total Toxic Organics: (40 CFR 469.12)

The term "total toxic organics" (TTO) means the sum of the concentrations for each of the following toxic organic components found in the discharge at a concentration greater than ten (10) micrograms per liter. The facility's local TTO and STO limits apply to all of the compounds listed below. Those compounds analyzed using EPA Method 601/602 or 624 are identified by a "■".

| | | | | |
|----------------------------|------------------------------|-----------------------------|---------------------------|---------------------|
| ■Acenaphthene | ■2-Chlorophenol | ■Methyl bromide | ■Diethyl phthalate | ■4,4-DDT |
| ■Acrolein | ■1,2-Dichlorobenzene | ■Bromoform | ■Dimethyl phthalate | ■4,4-DDE |
| ■Acrylonitrile | ■1,3-Dichlorobenzene | ■Dichlorobromomethane | ■1,2-Benzanthracene | ■4,4-DDD |
| ■Benzene | ■1,4-Dichlorobenzene | ■Chlorodibromomethane | ■Benzo(a)pyrene | ■Alpha-endosulfan |
| ■Benzidine | ■3,3-Dichlorobenzidine | ■Hexachlorobutadiene | ■3,4-Benzofluoranthene | ■Beta-endosulfan |
| ■Carbon tetrachloride | ■1,1-Dichloroethylene | ■Hexachlorocyclopentadiene | ■1,12-Benzofluoranthene | ■Endosulfan sulfate |
| ■Chlorobenzene | ■1,2-Trans-dichloroethylene | ■Isophorone | ■Chrysene | ■Endrin |
| ■1,2,4-Trichlorobenzene | ■2,4-Dichlorophenol | ■Naphthalene | ■Acenaphthylene | ■Endrin aldehyde |
| ■Hexachlorobenzene | ■1,2-Dichloropropane | ■Nitrobenzene | ■Anthracene | ■Heptachlor |
| ■1,2-Dichloroethane | ■1,3-Dichloropropylene | ■2-Nitrophenol | ■1,12-Benzoperylene | ■Heptachlor epoxide |
| ■1,1,1-Trichloroethane | ■2,4-Dimethylphenol | ■4-Nitrophenol | ■Fluorene | ■Alpha-BHC |
| ■Hexachloroethane | ■2,4-Dinitrotoluene | ■2,4-Dinitrophenol | ■Phenanthrene | ■Beta-BHC |
| ■1,1-Dichloroethane | ■2,6-Dinitrotoluene | ■4,6-Dinitro-o-cresol | ■1,2,5,6-Dibenzanthracene | ■Gamma-BHC |
| ■1,1,2-Trichloroethane | ■1,2-Diphenylhydrazine | ■N-nitrosodimethylamine | ■Indeno(1,2,3-cd) pyrene | ■Delta-BHC |
| ■1,1,2,2-Tetrachloroethane | ■Ethylbenzene | ■N-nitrosodiphenylamine | ■Pyrene | ■PCB-1242 |
| ■Chloroethane | ■Fluoranthene | ■N-nitrosodipropylamine | ■Tetrachloroethylene | ■PCB-1254 |
| ■Bis(2-chloroethyl) ether | ■4-Chlorophenyl phenyl ether | ■Pentachlorophenol | ■Toluene | ■PCB-1221 |
| ■2-Chloroethyl vinyl ether | ■4-Bromophenyl phenyl ether | ■Phenol | ■Trichloroethylene | ■PCB-1232 |
| ■2-Chloronaphthalene | ■Bis(2-chloroisopropyl)ether | ■Bis(2-ethylhexyl)phthalate | ■Vinyl chloride | ■PCB-1248 |
| ■2,4,6-Trichlorophenol | ■Bis(2-chloroethoxy)methane | ■Butyl benzyl phthalate | ■Aldrin | ■PCB-1260 |
| ■Parachlormeta cresol | ■Methylene chloride | ■Di-n-butyl phthalate | ■Dieldrin | ■Toxaphene |
| ■Chloroform | ■Methyl chloride | ■Di-n-octyl phthalate | ■Chlordane | ■TCDD |